

Approval Number 250355089  
Test Report: J-00486728 & J-00486730



2<sup>nd</sup> June 2025

Vialli GmbH  
Egerlander Strasse 16,  
Friedberg,  
Bayern,  
86316,  
Germany

Water Regulations Approval Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**POLYPROPYLENE- COMPONENTS.**

**5260**

'Vialli – De PP-RCT Pipes (with Aluminium Layer)'. Multi-layered, extruded pipes comprising of a green coloured PP-RCT inner and outer layer and an aluminium middle layer. For use with water up to 85°C.

**APPROVAL NUMBER: 250355089**  
**APPROVAL HOLDER: VIALLI GMBH**

The Scheme reserves the right to review approval.  
Approval 250355089 is valid between March 2025 and March 2030

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wrasapprovals.co.uk/approvals-directory/](http://www.wrasapprovals.co.uk/approvals-directory/)

Yours Faithfully

**Ian Hughes**  
**WRAS Approvals Manager**