

Approval Number 250155077
Test Report: J-00471176 & J-00471191



23rd May 2025

Vialli GmbH
Egerlander Strasse 16,
Friedberg,
Bayern,
86316,
Germany

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYPROPYLENE- COMPONENTS.

5260

'VIALLI-De PPR fittings'. Green coloured, injection moulded PPR fittings. For use with water up to 85°C.

APPROVAL NUMBER: 250155077
APPROVAL HOLDER: VIALLI GMBH

The Scheme reserves the right to review approval.
Approval 250155077 is valid between January 2025 and January 2030

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes
WRAS Approvals Manager