



Approval Number: 1608538  
Test Report: MAT/LAB 847K



13<sup>th</sup> October 2016

Mincom Trading LLC  
Industrial Area 3, Al Qusais,  
PO Box 232833,  
Dubai,  
UAE

Water Regulations Advisory Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**POLYPROPYLENE - COMPONENTS.**

5260

**Plastherm -PPRc**

'Plastherm PPR Pipe'. Green coloured, opaque, extruded PPR pipe. For use with water up to 85°C.

**APPROVAL NUMBER: 1608538**

**APPROVAL HOLDER: MINCOM TRADING LLC**

The Scheme reserves the right to review approval.

Approval 1608538 is valid between August 2016 and August 2021

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully



Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme