



Approval Number: 1704530
Test Report: MAT/LAB 875L rev. 2



Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

27th June 2017

Mincom Trading LLC
Industrial Area 3, Al Qusais,
PO Box 232833,
Dubai,
UAE

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYPROPYLENE - COMPONENTS.

5260

Plastherm - PPR - Glass Fiber Composite

'Plastherm PPR Glass Fibre Reinforced Pipe'. Extruded multi-layer pipe consisting of a green coloured polypropylene inner and outer layer with a black glass fibre middle layer. For use with water up to 85°C.

APPROVAL NUMBER: 1704530

APPROVAL HOLDER: MINCOM TRADING LLC

The Scheme reserves the right to review approval.
Approval 1704530 is valid between April 2017 and April 2022

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully



Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme