

Approval Number 240455059  
Test Report: J-00471176 & J-00471184



Water Regulations Approval Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

14<sup>th</sup> June 2024

Vialli GmbH  
Terminalstrasse Mitte 18,  
Munich,  
Bayern,  
85356,  
Germany

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**POLYPROPYLENE- COMPONENTS.**

**5260**

'VIALLI-De PPR SDR 6 & SDR 7.4 Pipes with Glass Fibre Middle Layer'.  
Extruded PPR pipes with a green coloured inner and outer layer and a red coloured, glass fibre middle layer.

For use with water up to 23°C.

**APPROVAL NUMBER: 240455059**  
**APPROVAL HOLDER: VIALLI GMBH**

The Scheme reserves the right to review approval.  
Approval 240455059 is valid between April 2024 and April 2029

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wrasapprovals.co.uk/approvals-directory/](http://www.wrasapprovals.co.uk/approvals-directory/)

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a horizontal line extending to the right.

**Ian Hughes**  
**WRAS Approvals Manager**